WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40771
Permit No.
Basin 85

NOTICE OF INTENT NO. 21693

1. OWNER Bill & Chris Butcher
MAILING ADDRESS 15 Chesney Ct.
Spanish Springs NV

ADDRESS AT WELL LOCATION
15 Chesney Ct.
Sparks, NV 89436

2. LOCATION NE ¼ SE ¼ Sec 31 T 21 N/S R 20 E Washoe County
PERMIT NO. N/A (Issued by Water Resources) 076-390-55 (Parcel No.) Spanish Springs (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & Boulders		0	6	6
Red Volc. cinders		6	22	16
Black Volc. Rock		22	125	103
Red Volc. Rock		125	190	65
Black Volc. Rock		190	300	110
Red Volc. Rock		300	405	105
Red & Black Volcs.	xx	405	440	35

Date started 2-26-93, 19
Date completed 3-11-93, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx.	30	430	5

8. WELL CONSTRUCTION
Depth Drilled 440 Feet Depth Cased 440 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 7/8" Inches		0 Feet	440 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	13	.188	-1	440

Perforations:
Type perforation Mill Slot
Size perforation 1/8" x 3"
From 360 feet to 440 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 60'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 60 feet to 440 feet

9. WATER LEVEL
Static water level 340 feet below land surface
Artesian flow none G.P.M. none P.S.I.
Water temperature good °F Quality cool

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EMDLCO Drilling (Contractor)
Address P.O. Box 8056 (Contractor)
Reno, NV 89507
Nevada contractor's license number issued by the State Contractor's Board 32166-C23
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
Signed Bruce Miller (By driller performing actual drilling on site or contractor)
Date 3-19-93

'93 MAR 24 A10:18
STATE ENGINEER

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627