WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40790
Permit No.
Basin 101

NOTICE OF INTENT NO. 22526

1. OWNER Help-U-Sell Realty/Gary Hutchings
MAILING ADDRESS 710 W. Williams Avenue
Fallon, NV 89406

ADDRESS AT WELL LOCATION
2911 Peachtree
Fallon, NV 89406

2. LOCATION SE ¼ SW ¼ Sec 6 T 18 N/X R 29 E Churchill County

PERMIT NO. (Issued by Water Resources) | 006-741-47 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [XX] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	11	11
Brown Clay		11	15	4
Brown Coarse Sand		15	17	2
Brown Fine Sand		17	28	11
Brown Clay		28	29	1
Brown COarse Sand	X	29	32	3

'93 MAR 29 P 2:04
STATE ENGINEER

Date started March 20, 19 93
Date completed March 20, 19 93

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 32 Feet Depth Cased 32 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	32 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	32

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 29 feet to 31 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [XX] Yes [ ] No
Depth of Seal 25
Placement Method: [X] Pumped [ ] Poured

Seal Type:
[X] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout

Gravel Packed: [XX] Yes [ ] No
From 25 feet to 32 feet

9. WATER LEVEL
Static water level 12' 3" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, INc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715

Signed [signature] (By driller performing actual drilling on site or contractor)
Date March 29, 1993

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627