WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40794
Permit No.
Basin 101

NOTICE OF INTENT NO. 22522

1. OWNER Tom RObinson
MAILING ADDRESS 5201 Candee Lane
Fallon, NV 89406

ADDRESS AT WELL LOCATION
1955 Western Avenue
Fallon, NV 89406

2. LOCATION NW ¼ NE ¼ Sec. 19 T. 19 N/~~S~~ R. 28 E. Churchill County
PERMIT NO. _____ Issued by Water Resources | 008-132-26 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	11	11
Brown Clay		11	18	7
Black Coarse Sand		18	23	5
Fine Brown Sand		23	36	13
Fine Green Sand		36	40	4
Fine Gray Sand		40	46	6
Black & Green Coarse Sand		46	49	3
Brown Coarse Sand	X	49	57	8

'93 MAR 25 P2:46
RECEIVED
STATE ENGINEERS OFFICE

Date started March 19, 1993
Date completed March 19, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 57 Feet Depth Cased 57 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	57 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	57

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 53 feet to 56 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 57 feet

9. WATER LEVEL
Static water level 10' 5" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling., Inc. Contractor
Address P.O. Box 1265 Contractor
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715

Signed Doug Parsons
By driller performing actual drilling on site or contractor
Date March 22, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627