WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40833
Permit No.
Basin 87 T

NOTICE OF INTENT NO. 49675

1. ~~OWNER~~ Consultant: Advanced Scientific Solutions
MAILING ADDRESS 3983 S. McCarren Blvd., SUite 201
Reno, NV 89502

Client:
ADDRESS AT WELL LOCATION TEET INC.
1750 Marietta Way
Sparks, NV.

2. LOCATION NE ¼ NE ¼ Sec. 17 T 19N N/S R 20 E Washoe County

PERMIT NO. M/O 374 MW#5 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [X] Other Tubex

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gray sandy gravel		0	2	2
Brown silty sand w/ gravel		2	6	4
Dark gray sand		6	10	4
DK gray gravelly sand		10	13.5	3.5
Dk gray to brown sandy gravel		13.5	20.5	7
Sandy gravel		20.5	22.5	2
Scattered cobbles & boulders		22.5	28.2	5.7

Date started February 21, 1992, 19
Date completed February 21, 1992, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NO TEST			

8. WELL CONSTRUCTION
Depth Drilled 28.2 Feet Depth Cased 28.2 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
9 5/16	0	28.2

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4" PVC		SCH 40	0	28.2
End Cap				
Locking Cap				

Perforations:
Type perforation Factory Slotted
Size perforation .020
From 8 feet to 28.2 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal Bentonite 2 foot
Placement Method: [ ] Pumped [X] Poured 7'
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 8 feet to 28.2 feet

9. WATER LEVEL
Static water level not known feet below land surface
Artesian flow n/k G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed (By driller performing actual drilling on site or contractor)
Date April 12, 1993

'93 APR 19 P1:17
RECEIVED
STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627