

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 40927  
 Permit No. 103  
 Basin 103  
 NOTICE OF INTENT NO. 21694

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Bill Carver & Betty Carver ADDRESS AT WELL LOCATION 5380 Sioux Ln.  
 MAILING ADDRESS 5380 Sioux Ln. 5380 Sioux Ln.  
Stagecoach NV Stagecoach NV  
 2. LOCATION SW  $\frac{1}{4}$  NE  $\frac{1}{4}$  Sec. 2 T. 17 (N/S R. 23 E. Lyon County  
 PERMIT NO. N/A 15-422-11 Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE  
 New Well  Replace  Recondition  Domestic  Irrigation  Test  Cable  Rotary  RVC  
 Deepen  Abandon  Other  Municipal/Industrial  Monitor  Stock  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand & Gravel		0	7	
Black Sand & Gravel		7	22	
Brown Sand & Gravel		22	90	
Gravel		90	145	
Brown Clay & Gravel		145	160	
Sandy Clay	x	160	210	
Brown Sand & Clay layers	x	210	300	

8. WELL CONSTRUCTION  
 Depth Drilled 300 Feet Depth Cased 300 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
12 1/4 Inches 0 Feet 300 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16	.188	-1	300

Perforations:  
 Type perforation Mill Slot  
 Size perforation 1/8" x 1"  
 From 120 feet to 140 feet  
 From 180 feet to 300 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50+  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 55 feet to 300 feet

9. WATER LEVEL  
 Static water level 160 feet below land surface  
 Artesian flow none G.P.M. none P.S.I.  
 Water temperature cool °F Quality good

Date started 3-10-93  
 Date completed 3-17-93

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	50	280	6

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EMDLCO Drilling Co. Contractor  
 Address P.O. Box 8056 Contractor  
Reno, NV  
 Nevada contractor's license number issued by the State Contractor's Board 32166-C23  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418  
 Signed Bruce Miller  
 By driller performing actual drilling on site or contractor  
 Date 4-4-93

'93 APR 15 10:39 AM  
 STATE ENGINEERS OFFICE