WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40849
Permit No.
Basin ~~104~~ 103

NOTICE OF INTENT NO. 22307

1. OWNER Michell Mattice
MAILING ADDRESS 123 Broadleaf LN
Carson City NV 89706

ADDRESS AT WELL LOCATION NA - 2 Miles Above Mexican Dam Sierra Vista Lane

2. LOCATION SW ¼ NE ¼ Sec. 2 T. 14 N/S R. 19 20 E. Garson County

PERMIT NO. NA (Issued by Water Resources) | 10-508-10 (Parcel No.) | 010-503-10 (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☑ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Coarse Sand		0	35	35 Ft
Gravels		35	55	20 Ft
Sands And Gravels		55	75	20 Ft
Gravels	✓	75	160	85 Ft
Broken Shale and Gravels	✓	160	200	40 Ft

'93 APR 21 A10:26
RECEIVED
STATE ENGINEERS OFFICE

Date started 3/16/93, 1993
Date completed 3/18/93, 1993

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air Developed Well For 3 hours Produced 50 Gallens a min.			

8. WELL CONSTRUCTION
Depth Drilled 0-200 Feet Depth Cased 0-200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	200 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	3/16	+1	200

Perforations:
Type perforation Torch-cut
Size perforation 6 x 1/8 x 5 Rows
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 53 Feet
Placement Method: ☑ Pumped ☐ Poured

Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 53 feet to 200 feet

9. WATER LEVEL
Static water level 123 feet below land surface
Artesian flow NA G.P.M. 50 + P.S.I.
Water temperature cold °F Quality no tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LEACH Drilling Inc (Contractor)
Address Po Box 599 Silver Springs NV 89429 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740-T-2
Signed [signature] By driller performing actual drilling on site or contractor
Date 4/18/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627