

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19755

1. OWNER Steve Koch ADDRESS AT WELL LOCATION EMERSON DRIVE CARSON CITY
 MAILING ADDRESS Carson NV
 2. LOCATION NW 1/4 NE 1/4 Sec 5 T. 15 N. R. 20 E. CARSON County
 PERMIT NO. 8-113-12 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	5	5'
Firm Sand & Clay Seams		5	40	35'
Small Gravels		40	55	15'
Small amount of water	X			
Soft Brown Clay		55	80	25'
Firm D.C. Sands		80	110	30'
Broken D.C. WATER ZONE	XX	110	120	10'

8. WELL CONSTRUCTION
 Depth Drilled 120' Feet Depth Cased 120' Feet
 HOLE DIAMETER (BIT SIZE)
 From 1 1/4 Inches To 5.5 Feet
 From 10 Inches To 120 Feet
 From _____ Inches To _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>13.03</u>	<u>.188</u>		

Perforations:
 Type perforation Mill slot
 Size perforation 3/16 X 3/32
 From 100 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 51'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 31 feet to 120' feet

9. WATER LEVEL
 Static water level 60' feet below land surface
 Artesian flow _____ G.P.M. 12-15 P.S.I.
 Water temperature Cold °F Quality Good

Date started 4-9, 1993
 Date completed 4-10, 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>12-15</u>	<u>30</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A & M PUMP CO.
 Address Carson City, Nevada
 Nevada contractor's license number 31839
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
 Signed Joe Smith
 By driller performing actual drilling on site or contractor
 Date 4/12/93

93 APR 16 P 1116
 RECEIVED
 STATE ENGINEERS OFFICE