WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40854
Permit No.
Basin 104

NOTICE OF INTENT NO. 26567

1. OWNER KEITH SCOTT
MAILING ADDRESS 4060 EAGLE MOUNTAIN WELLINGTON, NV 89444
ADDRESS AT WELL LOCATION 4060 EAGLE MOUNTAIN WELLINGTON, NV 89444

2. LOCATION S 1/2 ¼ ¼ Sec. 11 T. 10 N/S R. 22 E. DOUGLAS County
PERMIT NO. (Issued by Water Resources) APN 37 17021 (Parcel No.) TOPAZ RANCH ESTATES (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	2	
OVER BURDEN GRAV. & BOUL.		2	52	
FRACT. GRN SERPENTEEN		52	80	
FRACT GRN W/BRN CLAY		80	104	
FRACT. GRN SERP.		104	118	
FRACT GRN W/BRN CLAY		118	148	
FRACT GRAY SERP		148	160	
FRACT GRN SERP. W/BN CLAY		160	238	
FRACT GRN SERP. LESS CLAY		238	255	
FRACT. GRAY SERP.	WB	255	266	
FRACT GRN SERP W/GRAY CLAY		266	303	
FRACT GRAY SERP. SOME CLAY	WB	303	318	
FRACT GRN SERP W/GRAY CLAY		318	345	
FRACT GRN SERP. SOME CLAY	WB	345	360	
LOST CIRC. AT 346				

Date started 3-10, 1993
Date completed 3-19, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+	200	5

8. WELL CONSTRUCTION
Depth Drilled 360 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
9 7/8	0	360

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		188	0	360

Perforations:
Type perforation FACTORY
Size perforation 3/32" x 3"
From 360 feet to 340 FAC feet
From 340 feet to 320 TC feet
From 320 feet to 300 FACT feet
From 300 feet to 240 TC feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 360 feet to 50 feet

9. WATER LEVEL
Static water level 145 feet below land surface
Artesian flow G.P.M. 20+ P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ED MILLER (Contractor)
Address P.O. BOX 92 (Contractor)
SMITH, NV 89444
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed Gerald W. Plummer (By driller performing actual drilling on site or contractor)
Date 3-19-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627