

N08 E37H

SECTION 04AD

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 10855

Permit No. 59008

Basin 136

I

NOTICE OF INTENT NO. 22317

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Rock Spring Ranch/DBA R.O. Livestock ADDRESS AT WELL LOCATION No. Physical Address
 MAILING ADDRESS P.O. Box 2050 Section 04AD Black Spring Well
King City, Ca. 93930
 2. LOCATION SE 1/4 SW 1/4 Sec 20 T. 8N R. 38 1/2 E. Nye County
 PERMIT NO. 56687-N-39859008
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
GRANITE WASH- Some loose but stable gravel		0	50	
white granite		50	305	
WASH- NO CHANGES- TAN-Buff clay- stone/sandstone		305	595	
SMALL gravel- Rounded & stained TAN-Buff clay- stone/sandstone	✓	395	605	10
		605	630	

93 APR 21 AM 12:29
STATE ENGINEERS CFTI

8. WELL CONSTRUCTION
 Depth Drilled 630 Feet Depth Cascd 630 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>1 1/4</u> Inches	<u>0</u> Feet <u>50</u> Feet
<u>8 3/4</u> Inches	<u>50</u> Feet <u>630</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.81</u>	<u>1.88</u>	<u>+1</u>	<u>630</u>

Perforations:
 Type perforation Milled
 Size perforation 1/8 X 3
 From 585 feet to 615 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From (605) feet to 630 BLANK (Cg) feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 525 feet below land surface
 Artesian flow 5 G.P.M. _____ P.S.I.
 Water temperature C °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Waytek Drilling Co. Contractor
 Address 2220 Stone Dr Reno Nv 89511 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 24521
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
 Signed Les Waytek
 By driller performing actual drilling on site or contractor
 Date 4-16-93

Date started 3-31 1993
 Date completed 4-8 1993

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>5</u>		<u>4 hrs.</u>