WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40957
Permit No.
Basin 212

NOTICE OF INTENT NO. 10268

1. OWNER City of HENDERSON
MAILING ADDRESS 240 WATER STREET
HENDERSON, NV. 89015

ADDRESS AT WELL LOCATION 2400 MOSER DRIVE
HENDERSON, NV. 89015

2. LOCATION SE ¼ SE ¼ Sec. 30 T. 21 N(S) R. 63 E. CLARK County
PERMIT NO. MO-2252 (Issued by Water Resources) Parcel No. WASTEWATER TREATMENT PLANT #3 (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVELLY SAND WITH SILT (FROM PREVIOUS WELL LOG)		0'	25'	25'
BROWN MEDIUM TO COARSE SAND, SOME fine to medium GRAVEL (SATURATED)		25'	45'	20'
(HEAVING SANDS)				

RECEIVED
APR 07 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started MARCH 11, 1993
Date completed MARCH 11, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 45 Feet Depth Cased 39.5 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	45 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	40	0.154	0	17.00
4/2	40/40	0.154	17.00	34.50
2	40	0.154	34.50	39.50

Perforations:
Type perforation FACTORY Slotted PREPACKED SCREEN
Size perforation 0.020 inch
From 17.00 feet to 34.50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 14 feet
Placement Method: ☒ Pumped ☐ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No PREPACKED SCREEN
From 16.00 feet to 34.50 feet

9. WATER LEVEL
Static water level 16.00 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality NON-POTABLE

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name TERRY SUMP (Contractor)
Address 1860 OBISPO #H SIGNAL HILL CA. (Contractor)

Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1872-M

Signed Terry Sump (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627