WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40967
Permit No.
Basin 49

NOTICE OF INTENT NO. 21019

1. OWNER PEDRO Quintero
MAILING ADDRESS 545 South 5th Trl #8
Elko, NV 89801

ADDRESS AT WELL LOCATION West side of Indiana between 3rd and 4th street

2. LOCATION NE ¼ SW ¼ Sec. 7 T. 34 N/S R. 56 E. County
PERMIT NO. Issued by Water Resources | 32004 36 6 Parcel No. | Last Chance #3 Subdivision Name

3. WORK PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[x] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[x] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Sand some clay		2	14	12
Brown siltstone		14	68	54
Gray siltstone		68	150	78
Brown siltstone	X	150	220	70

'93 APR 28 AM 11:19
STATE ENGINEER'S OFFICE

Date started April 7, 19 93
Date completed April 9, 19 93

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [x] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		4

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10-5/8 Inches	0 Feet	220 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13	.188	+1	220

Perforations:
Type perforation Mill slot
Size perforation 3/16 x 3
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [x] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [x] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [x] Yes [ ] No
From 50 feet to 220 feet

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. Contractor
Address P.O. Box 850 Contractor
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed David Owens
By driller performing actual drilling on site or contractor
Date 4-26-1993

(Rev. 3-91)
USE ADDITIONAL SHEETS IF NECESSARY
(O)-627