WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40982
Permit No.
Basin 6-84

NOTICE OF INTENT NO. 21214

1. OWNER Country Sleep Center
MAILING ADDRESS 2200 S Virginia Reno NV
ADDRESS AT WELL LOCATION Same

2. LOCATION NE ¼ NE ¼ Sec 7 T 18 N/S R 20 E Washoe County
PERMIT NO. m/s 490 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG M-3

Material	Water Strata	From	To	Thickness
The existing well was in poor condition. It was pressure grouted from 15' to surface in one stage using 5 bags of portland type II cement with 6 gallon/bag mixture, pushing the well water to the surface.				

RA log # 38059

STATE ENGINEER 93 MAY 12 A11:13

Date started 12/23, 1972
Date completed 12/23, 1972

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 15 Feet Depth Cased 15 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	15 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		Sch 40	0	15

Perforations:
Type perforation Factory slot
Size perforation .020
From 5 feet to 15 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 3.5
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 3.5 feet to 15 feet

9. WATER LEVEL
Static water level 6.5 feet below land surface
Artesian flow n/a G.P.M. n/a P.S.I.
Water temperature Cold °F Quality n/a

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Andreson Drilling (Contractor)
Address 1635 Belford Rd, Reno NV, 89509 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed [signature] By driller performing actual drilling on site or contractor
Date 3/1/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627