WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40984
Permit No.
Basin CST

NOTICE OF INTENT NO. 21667

1. ~~OWNER~~ Consultant: Pezonella Associates, Inc.
MAILING ADDRESS 520 Edison Way
Reno, NV. 89502

ADDRESS AT WELL LOCATION Reson, Inc.
208 E. 4th St.
Reno, NV 89502

2. LOCATION SE ¼ NE ¼ Sec. 11 T. 19N N/S R. 19 E. Washoe County
PERMIT NO. M/W 619-A MW#2
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [X] Other Tubex

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt & Gravel Base		0	1	1
Brown Sandy Clay		1	19	18
Light Brown Gravel,		19	35	16
Cobbles & Boulders				
w/ Sand.				

'93 APR 29 AM 10:45
STATE ENGINEER'S OFFICE

Date started March 10, 1993, 19
Date completed March 11, 1993, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NO TEST			

8. WELL CONSTRUCTION
Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9 5/16 Inches	0 Feet	35 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4" PVC		SCH 40	0	35
End Cap				
Locking	Cap			

Perforations:
Type perforation Factory Slotted
Size perforation 0.020"
From 15 feet to 35 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 12'
Placement Method: [ ] Pumped [X] Poured
BEntonite SEal @ 12'-14'
Gravel Packed: [X] Yes [ ] No
From 14 feet to 35 feet

Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

9. WATER LEVEL
Static water level 25.56 feet below land surface
Artesian flow Not Known G.P.M. P.S.I.
Water temperature n/k °F Quality n/k

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NV. 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed [signature] (By driller performing actual drilling on site or contractor)
Date April 16, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627