

OFFICE USE ONLY
 Log No. A1021
 Permit No. _____
 Basin 92B

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17278

1. OWNER GEORGE PEAK 9/0 ERGS, INC. ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS PO BOX 11525 9205 LEMMON VALLEY DR.
RENO, NV 89510 LEMMON VALLEY, NV
 2. LOCATION SW 1/4 SW 1/4 Sec 34 T 21 N R 19 E WASHOE County
 PERMIT NO. M10 445B Parcel No. _____ Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG MW-2

Material	Water Strata	From	To	Thickness
<u>DARK BROWN SILTY SAND (SM)</u>	<u>NO</u>	<u>0</u>	<u>5'</u>	<u>5'</u>
<u>DARK BROWN CLAYEY SAND (SC)</u>	<u>NO</u>	<u>5'</u>	<u>11.5'</u>	<u>6.5'</u>
<u>DARK BROWN SANDY CLAY (CL/CH)</u>	<u>NO</u>	<u>11.5'</u>	<u>19'</u>	<u>7.5'</u>
<u>BROWN GRAVEL (GP)</u>	<u>NO</u>	<u>19'</u>	<u>25'</u>	<u>6'</u>
<u>BROWN SANDY CLAY (CL)</u>	<u>YES</u>	<u>25'</u>	<u>39'</u>	<u>14'</u>

'93 APR 22 P1114
 RECEIVED
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 39 Feet Depth Cased 38.5 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet
 From 0 Feet To 39 Feet
 From _____ Inches To _____ Feet
 From _____ Inches To _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>	<u>PVC</u>	<u>SCHED. 40</u>	<u>0</u>	<u>38.5</u>

Perforations:
 Type perforation SLOTTED
 Size perforation 0.020"
 From 14 feet to 38 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 10' (BENTONITE) Neat Cement
 Placement Method: Pumped Cement Grout
 Poured (PLUG PLUM 10'-12') Concrete Grout
 Gravel Packed: Yes No NO. 3 SAND SILICA
 From 12 feet to 39 feet


9. WATER LEVEL
 Static water level 25 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name PETER KRAATZ Contractor
 Address 2652 POWDER DR. Contractor
RENO, NV 89503
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1629
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 4-21-93

Date started 2/25, 1993
 Date completed 2/25, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			



PROJECT	Valley Auto Center	DRILLING COMPANY	PEZZONELLA ASSOCIATES INC
LOCATION	Lemmon Valley, Nevada	DATE DRILLED	2/25/93
JOB NUMBER	45101	SURFACE ELEVATION	
GEOLOGIST	Barry Cernoch/Peter Kraatz	TOTAL DEPTH OF HOLE	39 Feet
DRILL RIG	10 in. Hollow Stem Auger	WATER LEVEL	25 Feet