

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 41033
 Permit No. 1022
 Basin 1022

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 2384

1. OWNER CARIS PERSONS ADDRESS AT WELL LOCATION 2595 CAUGHER ST. SILVER SPRINGS NV 89429
 MAILING ADDRESS 2595 CAUGHER ST. SILVER SPRINGS NV 89429
 2. LOCATION NW 1/4 NE 1/4 Sec 29 T 17 N/S R 25 E County LYON
 PERMIT NO. 17-452-02 Riverside Sub Div. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fine To Coarse Brown Sand		0	30	30
Gray clay & sand		30	45	15
Gray Fine To coarse sand	X	45	80	35
Brown clay & sand		80	135	55
Coarse Brown sand	X	135	180	45

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 1/4 Inches 0 Feet 180 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>+1</u>	<u>180</u>

Perforations:
 Type perforation MILL
 Size perforation 3 1/2 X 3
 From 160 feet to 180 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 FT Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 180 feet

9. WATER LEVEL
 Static water level 35 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

Date started 4-20 1993
 Date completed 4-22 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>18</u>	<u>8</u>	<u>2 Hrs.</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ace Drilling & Development Contractor
 Address P.O. Box 668 Contractor
Silver Springs NV 89429
 Nevada contractor's license number issued by the State Contractor's Board 14299
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 726
 Signed H.L. [Signature]
 By driller performing actual drilling on site or contractor
 Date 4-23-93

APR 27 10:17
 RECEIVED
 STATE ENGINEERS OFFICE