

OFFICE USE ONLY  
 Log No. 41038  
 Permit No. 103  
 Basin 103

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21803

1. OWNER Patricia Dinan/ Diane Gordon ADDRESS AT WELL LOCATION 215 Imperial Rd  
 MAILING ADDRESS 215 Imperial Rd Dayton, Nv 89403 Lot 27  
 2. LOCATION se 1/4 NE 1/4 Sec 9 T 16 N/S R 22 E Lyon County Dayton Valley Ranches  
 PERMIT NO. 19-142-02 - Dayton Valley Ranches  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	3	3
Volcanic boulders & dirt		3	57	53
Soft volcanic rock & little tan clay		57	177	120
Bottom <u>18</u> feet filled with gravel				
T.D. <u>159</u> ft				

8. WELL CONSTRUCTION  
 Depth Drilled 177 Feet Depth Cased 159 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 55 Feet  
8 1/2 Inches 55 Feet 177 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+ 1</u>	<u>159</u>

 Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3  
 From 119 feet to 139 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 177 feet

93 APR 20 10:33  
 RECEIVED  
 STATE ENGINEERS OFFICE

9. WATER LEVEL  
 Static water level 90 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality \_\_\_\_\_

Date started 3/9/93, 19\_\_\_\_\_  
 Date completed 3/11/93, 19\_\_\_\_\_  
 7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15+</u>		<u>1 3/4</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling & Well Service, Inc  
 Address 625 Spice Ilands Dr Suite L  
Sparks, Nv 89431  
 Nevada contractor's license number 15291  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1804  
 Division of Water Resources, the on-site driller  
 Signed Roger M. Thrall  
 By driller performing actual drilling on site or contractor  
 Date Roger M. Thrall - President 3/12/93