

OFFICE USE ONLY
 Log No. 41045
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22278

1. OWNER NEVADA JOHNSON ADDRESS AT WELL LOCATION 1493 WILLOW CREEK
 MAILING ADDRESS GARDNERVILLE GARDNERVILLE

2. LOCATION NW 1/4 SW 1/4 Sec 35 T 13 N R 20 E DOUGLAS County WILDFLOWER
 PERMIT NO. 23-540-11 Parcel No. _____ Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY w/COBBLES		0	17	17
SAND + GRAVEL		17	23	6
SANDY CLAY w/GRAVEL		23	60	37
CLAY		60	76	16
SANDY CLAY w/COBBLES		76	123	47
SAND + GRAVEL	✓	123	156	33
SANDY CLAY		156	160	4

'93 APR 27 AID:51
 RECEIVED
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>160</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 x 3/32
 From 140 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 50 feet to 160 feet

Date started 4/6, 1992
 Date completed 4/8, 1992

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>	<u>—</u>	<u>1</u>

9. WATER LEVEL
 Static water level 38 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDCO EXPLORATION, INC. Contractor
 Address 7780 CURRY RD. Contractor
FALLON, NV 89406
 Nevada contractor's license number 27673
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1726
 Division of Water Resources, the on-site driller.
 Signed Pat A. Moore
 By driller performing actual drilling on site of contractor
 Date 4/8/93