WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 41067
Permit No.
Basin 184

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14044

1. OWNER Minel Inc.
MAILING ADDRESS 309 Washington SE
Albuquerque, NM 87108

ADDRESS AT WELL LOCATION
Hiway 6 & 50 Osceola District
White Pine County NV

2. LOCATION SE ¼ NE ¼ Sec. 21 T. 14 N/S R. 67 E White Pine County
PERMIT NO. ~~25524~~ 58303-T (Issued by Water Resources) | 12-160-11 (Parcel No.) | none (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☒ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
soil, gravel		0	1	1
hardpan, boulders		1	60	59
sand, gravel, water	x	60	65	5
boulders, gravel		65	85	20
sand, gravel, water	x	85	90	5
sandstone, gravel		90	160	70
sand, gravel, water	x	160	165	5
sandstone, gravel		165	211	46

RECEIVED 93 MAY 11 P2:50 STATE ENGINEERS OFFICE

Date started March 23, 19~~93~~ 93
Date completed April 13, 1993

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	220	190	16

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12 inches Total depth 211 feet
..... inches
..... inches
Casing record
Weight per foot 31.37 lb./ft. Thickness .250

Diameter	From	To
12 inches	0 feet	208 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 ft. feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 85 feet

Perforations:
Type perforation factory
Size perforation 1/8" x 2 1/2"
From ~~10~~ 60 feet to 70 feet
From 89 feet to 109 feet
From 128 feet to 208 feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 57 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Ave. Ely, NV 89301 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada contractor's driller's number issued by the Division of Water Resources 641
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641
Signed Jerald D. Christiansen (By driller performing actual drilling on site or contractor)
Date May 6, 1993

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627