


Log No. 41671

Permit No. \_\_\_\_\_

Basin. 162



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 11616

1. OWNER Bill Moore ADDRESS AT WELL LOCATION Lot 94 TOLYAST  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NE 1/4 NW 1/4 Sec. 30 T. 19S N/S R. S3 E Nye County \_\_\_\_\_  
 PERMIT NO. 29-462-15 Parcel No. \_\_\_\_\_ Subdivision Name Valley View Acres

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	6	6
caliche		6	8	2
Clay		8	35	27
caliche		35	37	2
Clay		37	52	15
caliche	WB	52	54	2
Clay		54	73	19
caliche	WB	73	75	2
Clay		75	95	20
caliche	WB	95	100	5

8. WELL CONSTRUCTION  
 Depth Drilled 100 Feet Depth Cased 100 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 0 Feet 100 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.92</u>	<u>.188</u>	<u>0</u>	<u>100</u>

Perforations:  
 Type perforation Factory Saw cut  
 Size perforation 1/8 x 3  
 From 80 feet to 100 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 100 feet

RECEIVED  
 APR 23 1993  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 4-5, 1993  
 Date completed 4-9, 1993

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 48 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Great Basin Drilling Contractor  
 Address ACR 78 Box 80358 Contractor  
Pahrump NV 89041  
 Nevada contractor's license number 30880 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
 Signed Thomas Dan  
 By driller performing actual drilling on site or contractor  
 Date 4-17-93

