



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10418

1. OWNER NIM ROD SMITH ADDRESS AT WELL LOCATION BELLVISTA RD. PAHRUMP NV.  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SW 1/4 NE 1/4 Sec. 35 T 19 N/S R. 53 E NYE County  
 PERMIT NO. 27-411-25 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
ROCK + CLAY		0	15	15
CLAY + GRAVEL		15	45	30
CLAY		45	55	10
CEMENTED GRAVEL		55	89	34
CLAY + GRAVEL		89	120	31
SAND + GRAVEL		120	188	68
CALICHE	Tr.	188	192	4
CEMENTED GRAVEL		192	242	50
GRAVEL	W.B.	242	325	83

8. WELL CONSTRUCTION  
 Depth Drilled 325 Feet Depth Cased 325 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 3 1/2 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>325</u>

Perforations:  
 Type perforation FACTORY SAW CUT  
 Size perforation 8 INCH BY 3 INCH  
 From 325 feet to 305 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 325 feet to 50 feet

9. WATER LEVEL  
 Static water level 220 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 60.0 °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GREAT BASIN DRILLING Contractor  
 Address HCR 78 BOX 80358 Contractor  
PAHRUMP NV. 89041  
 Nevada contractor's license number 30880  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1573  
 Division of Water Resources, the on-site driller  
 Signed Dannie Brown  
 By driller performing actual drilling on site or contractor  
 Date 3-22-93

Date started 2-18 1993  
 Date completed 2-26 1993

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<b>RECEIVED</b>		
<b>MAR 25 1993</b>		
Div. of Water Resources		
Branch Office - Las Vegas, NV		