WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41087
Permit No.
Basin 162

NOTICE OF INTENT NO. 11584

1. OWNER Kings Land
MAILING ADDRESS
ADDRESS AT WELL LOCATION Lot 70 ~~Retreat~~ Medicine Man Rd

2. LOCATION NE ¼ SE ¼ Sec. 13 T. 20S N/S R. 52 E. Nye County
PERMIT NO. (Issued by Water Resources) 28-641-01 (Parcel No.) Charleston Park Ranchos (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	12	12
Caliche		12	14	2
Clay		14	22	8
Caliche		22	25	3
Clay		25	46	21
Caliche		46	48	2
Clay		48	62	14
Caliche	WB	62	64	2
Clay		64	76	12
Caliche	WB	76	78	2
Clay		78	92	14
Caliche	WB	92	94	2
Clay		94	118	24
Caliche	WB	118	122	4
Clay		122	137	15
Caliche	WB	137	140	3

RECEIVED
APR 01 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 3 - 22, 1993
Date completed 3 - 26, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation 1/8 x 3
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Great Basin Drilling
Address (Contractor) HCR79 Box 80358
Pahrump NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dunn (By driller performing actual drilling on site or contractor)
Date 3-30-93

(Rev. 3-91)
USE ADDITIONAL SHEETS IF NECESSARY
(O)-627