



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 11623

1. OWNER John Hansen ADDRESS AT WELL LOCATION Lot 36 Retread
 MAILING ADDRESS _____
 2. LOCATION NE 1/4 SW 1/4 Sec. 18 T. 20S N/S R. 53 E Nye County _____
 PERMIT NO. 36-202-04 Parcel No. _____ Subdivision Name Charleston Park

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	7	7
caliche		7	9	2
Clay		9	18	9
caliche		18	20	2
Clay		20	40	20
caliche		40	43	3
Clay		43	56	13
caliche	WB	56	58	2
Clay		58	71	13
caliche	WB	71	73	2
Clay		73	87	14
caliche	WB	87	89	2
Clay		89	101	12
caliche	WB	101	104	3
Clay		104	116	12
caliche	WB	116	118	2
Clay		118	122	4
caliche	WB	122	124	2
Clay		124	137	13
caliche	WB	137	140	3

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation Factory SAW CUT
 Size perforation 1 1/8 x 3
 From 120 feet to 140 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

RECEIVED

APR 01 1993

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 3-22, 1993
 Date completed 3-26, 1993

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL
 Static water level 48 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address Her 78 Box 80358 Contractor
Ahrump NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Dan
 By driller performing actual drilling on site or contractor
 Date 3-29-93