

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.240

Log No. 41137
Permit No. _____
Basin _____

NOTICE OF INTENT NO. 11626

1. OWNER Tracey Sisson ADDRESS AT WELL LOCATION Lot 5 DEANA ST
MAILING ADDRESS _____
2. LOCATION NW 1/4 NE 1/4 Sec 11 T 21S N/S R 53 E Nye County
PERMIT NO. 44-293-13 Issued by Water Resources Parcel No. Joyelyn Estates Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Monitor Stock Test Other _____
5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	12	12
caliche		12	14	2
Clay		14	25	11
caliche		25	27	2
Clay		27	37	10
caliche		37	39	2
Clay		39	54	15
caliche	WB	54	56	2
Clay		56	81	25
caliche	WB	81	83	2
Clay		83	101	18
caliche	WB	101	103	2
Clay		103	115	12
caliche	WB	115	118	3
Clay		118	126	8
caliche	WB	126	128	2
Clay		128	133	5
caliche	WB	133	136	3
Clay		136	140	4

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet
HOLE DIAMETER (BIT SIZE)
From 12 1/4 Inches To 0 Feet 140 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.199</u>	<u>0</u>	<u>140</u>

Perforations:
Type perforation Factory Sawcut
Size perforation 1/8 x 3
From 120 feet to 140 feet
From _____ feet to _____ feet
Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
Depth of Seal 50
Placement Method: Pumped Poured
Gravel Packed: Yes No
From 50 feet to 140 feet

RECEIVED

APR 01 1993

Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 3-29 1993
Date completed 3-29 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling Contractor
Address ACR 78 Box 80358 Contractor
Pahrump NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas D...
By driller performing actual drilling on site or contractor
Date 3-29-93