



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 11620

1. OWNER LEWIS CAMPBELL ADDRESS AT WELL LOCATION JADE AV. SANDY VALLEY
 MAILING ADDRESS _____
 2. LOCATION: SW $\frac{1}{4}$ NE $\frac{1}{4}$ Sec. 6 T. 25 N/S R. 57 E. CLARK County
 PERMIT NO. 590-920-001 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY LOAM		0	3	3
CLAY		3	10	7
CALICHE		10	13	3
CLAY		13	20	7
CALICHE		20	25	5
CLAY		25	52	27
CALICHE	W.B.	52	56	4
CLAY		56	68	12
CALICHE	W.B.	68	71	3
CLAY		71	81	10
CALICHE	W.B.	81	83	2
CLAY		83	98	15
CALICHE	W.B.	98	102	4
CLAY		102	112	10
CALICHE	W.B.	112	118	6
CLAY		118	120	2

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 120 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 7/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>120</u>

Perforations:
 Type perforation FACTORY SAW CUT
 Size perforation 8 INCH BY 3 INCH
 From 120 feet to 100 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 120 feet to 50 feet

9. WATER LEVEL
 Static water level 45 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING Contractor
 Address HCR. 78 BOX 80358 Contractor
PAHRUMP NV. 89041
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
 Signed Daniel Brown
 By driller performing actual drilling on site or contractor
 Date 3-22-93

7. WELL TEST DATA
 TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

 Date started 3-16 1993
 Date completed 3-19 1993

RECEIVED
 MAR 25 1993
 Div. of Water Resources
 Branch Office - Las Vegas, NV