

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 41169
 Permit No. 1
 Basin 1
 NOTICE OF INTENT NO. 10695

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER Theron Hendrickson ADDRESS AT WELL LOCATION 1/4
 MAILING ADDRESS _____

2. LOCATION NW 1/4 SE 1/4 Sec. 22 T 19S N/S R. 60 E Clark County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Black Clay		0	6	
Brown Clay		6	15	
Caliche		15	18	
Clay		18	30	
Caliche		30	38	
Clay		38	60	
Caliche		60	85	
Clay		85	130	
Caliche		130	140	
Clay		140	160	
Clay and Water	xx	160	175	
Clay		175	230	
Clay and Water	xx	230	245	
Clay		245	350	
Caliche & Water	xx	350	406	

8. WELL CONSTRUCTION
 Depth Drilled 406 Feet Depth Cased 406 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 1/4 Inches 0 Feet 406 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"	16.94	.188	+1	406

Perforations:
 Type perforation Factory
 Size perforation 3/16 x 8 row
 From 362 feet to 386 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 200 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 200 feet to 406 feet

9. WATER LEVEL
 Static water level 121 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Vernon H. Dimick Contractor
 Address 3035 S. Torrey Pines
Las Vegas, Nev. 89102
 Nevada contractor's license number 10062
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 552
 Division of Water Resources, the on-site driller
 Signed Vernon H. Dimick
 By driller performing actual drilling on site or contractor
 Date 3-15-93

Date started 3/9/93, 19_____
 Date completed 3/15/93, 19_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
 MAR 22 1993
 Div. of Water Resources
 Branch Office - Las Vegas, NV

