

Log No. 41184

Permit No. 56914

Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 8478

1. OWNER CHRIS COLLIER ADDRESS AT WELL LOCATION JENSEN T RED CLUNCH
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 NW 1/4 Sec. 6 T 20 N/S R. 60 E CLARK County
 PERMIT NO. 56914 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY, GRAVEL + ROCKS		0	30	30
CHIT. GRAVEL W/ STRKS. OF CLAY + GRAVEL		30	160	130
CLAY		160	180	20
CHIT. GRAVEL W/ STRKS. OF SANDY CLAY + GRAVEL		180	350	170
HARD CHIT. GRAVEL		350	380	30
CHIT. GRAVEL W/ STRKS. OF CLAY & GRAVEL		380	715	335

8. WELL CONSTRUCTION
 Depth Drilled 715 Feet Depth Cased 715 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 715
12 1/4 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>+1</u>	<u>715</u>

Perforations:
 Type perforation FACTORY
 Size perforation 18 x 2 1/2
 From 6 3/5 feet to 6 5/5 feet
 From 6 9/5 feet to 6 9/5 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 715 feet

RECEIVED

MAR 26 1993

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 3-8 1993
 Date completed 3-11 1993

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name DESERT DRILLING Contractor
 Address 6475 GARY AVE Contractor
LAS VEGAS, NV. 89139
 Nevada contractor's license number issued by the State Contractor's Board 34274
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1594
 Signed Pindall Conner
 By driller performing actual drilling on site or contractor
 Date 3-15-93