Corrected

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

UNLV well
PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41187
Permit No. 58461 T
Basin

NOTICE OF INTENT NO. 11681 & 11682

1. OWNER City of North Las Vegas
MAILING ADDRESS P.O. Box 4086
N. Las Vegas, NV 89036

ADDRESS AT WELL LOCATION Horse East of Thom 4734 Horse Dr.

2. LOCATION ~~NW~~ SW ¼ ~~SW~~ NW ¼ Sec. 7 T. ~~20~~ 19S S/R 61 E Clark County

PERMIT NO. 58461T (Issued by Water Resources) 124-07-201-001 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
White clay		0	100	100
Gravel stringers & clay		100	140	40
Brown clay		140	200	60
Gravel & brown clay		200	280	80
Gravel		280	300	20
Br. clay & gravel mixed		300	340	40
Brown clay		340	360	20
Fractured gravel		360	380	20
Brown sandy clay		380	440	60
Stringers of grav. & clay		440	480	40
Clay		480	500	20
Clay & gravel		500	520	20

RECEIVED
APR 13 1993

Date started March 26, 1993
Date completed April 7, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 520 Feet Depth Cased 520 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	520 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.9	.188	+1	520

Perforations:
Type perforation Mill slots
Size perforation 2" x 1/8"
From 250 feet to 350 feet
From 400 feet to 500 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal ~~50~~ 200
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 200 ~~50~~ feet to 520 feet

9. WATER LEVEL
Static water level 122 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name THOMPSON DRILLING CO., INC. (Contractor)
Address 4185 West Harmon (Contractor)
Las Vegas, NV 89103

Nevada contractor's license number issued by the State Contractor's Board 4286A

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1489

Signed Richard K. Thompson
By driller performing actual drilling on site or contractor

Date April 9, 1993

USE ADDITIONAL SHEETS IF NECESSARY

Revised ~~[illegible]~~
7/22/16