WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41188
Permit No.
Basin 212

NOTICE OF INTENT No. 10689

1. OWNER Ingrid Hines
MAILING ADDRESS Same
ADDRESS AT WELL LOCATION 5355 W. Sahara L.V. 89102

2. LOCATION NW ¼ NE ¼ Sec. 12 T. 21 N/S R. 60 E. Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	
Caliche		5	15	
Clay		15	80	
Caliche		80	105	
Caliche & Water	xx	105	120	
Clay and Sand		120	220	
Gravel & Water	xx	220	250	
Cemented Gravel		250	290	
Gravel & Water		290	350	
Cement old well				
9 sack grout, pumped				
casing parted at 110 ft				
and casing parted at 200 ft.				

RECEIVED
MAR 08 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started January 23, 1993, 19
Date completed Feb 4, 1993, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 350 Feet Depth Cased 350 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4"	Inches	0 Feet	350 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"	16.94	.188	+1	350

Perforations:
Type perforation Factory
Size perforation 3/16 x 8 row
From 310 feet to 330 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 220
Placement Method: ☒ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 220 feet to 350 feet

9. WATER LEVEL
Static water level 156 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick (Contractor)
Address 3035 S. Torrey Pines (Contractor)
Las Vegas, Nevada 89102
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources the on-site driller 552
Signed V. H. Dimick (By driller performing actual drilling on site or contractor)
Date Mar 8, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627