WHITE–DIVISION OF WATER RESOURCES
CANARY–CLIENT'S COPY
PINK–WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41197
Permit No.
Basin 212

NOTICE OF INTENT NO. 23106

1. OWNER Kleinfelder, Inc.
MAILING ADDRESS 6850 So. Paradise
Las Vegas, Nevada 89119

ADDRESS AT WELL LOCATION 4505 Maryland Pkwy.

2. LOCATION NE ¼ SW ¼ Sec 22 T 21 N/S R 61 E Clark County
PERMIT NO. M0227 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	2"	2"
Aggregate Base		2"	1'	10"
Gravelly Sand		1'	2'	1'
Silty Sand		2'	5'	3'
Caliche		5'	7'	2'
Gravelly Sand		7'	10.5'	3.5'
Sandy Silt		10.5'	11.5'	1'
Sandy Clay		11.5'	13'	1.5'
Sandy Silt		13'	14'	1'
Clayey Sand		14'	16'	2'

RECEIVED
MAY 04 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started April 2, 1993
Date completed April 15, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 15 Feet Depth Cased @15 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 Inches	0 Feet	15 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 (PVC)				

Perforations:
Type perforation Slotted
Size perforation
From 8 feet to 15 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 7 ft.
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 9'4" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name TERRY SUMP
Contractor
Address 1860 OBISPO #H
Contractor
SIGNAL HILL CA. 90806
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1872-NV
Signed Terry Sump
By driller performing actual drilling on site or contractor
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627