WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 41198
Permit No.
Basin 212

NOTICE OF INTENT NO. 10154

1. OWNER: CAL NEV PIPELINE
MAILING ADDRESS: C/o Converse Consultants, 4670 S. Polaris Ave., Las Vegas
ADDRESS AT WELL LOCATION: CAL NEV PIPELINE, Corner of Valley View & Hacienda, Las Vegas, Nevada

2. LOCATION: SE ¼ NE ¼ Sec. 30 T. 21 N/S R. 61 E. Clark County
PERMIT NO. Mo-2262 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| sandy gravel | | 0' | 4' | 4' |
| caliche | | 4' | 14' | 10' |
| gravelly sand | | 14' | 36' | 22' |
| caliche | | 36' | 48' | 12' |
| gravelly sand | | 48' | 52' | 4' |
| silty clay | | 52' | 80' | 28' |

RECEIVED
MAY 04 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 03.31, 1993
Date completed 03/31, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 80 Feet Depth Cased 80 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From (Feet) | To (Feet) |
|---|---|---|
| 8 | 0 | 80 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2" | .7 lbs | SCH. 40 | 0 | 80 |
| | | | | |
| | | | | |

Perforations:
Type perforation: factory slotted
Size perforation: 0.020
From 40 feet to 80 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-36/34-36 Bent.
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 36 feet to 80 feet

9. WATER LEVEL
Static water level 60' (approx.) feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RICHARD LEBLANC (Contractor)
Address 4670 S. Polaris Ave. (Contractor)
Las Vegas, Nevada 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1817
Signed R. LeBlanc (By driller performing actual drilling on site or contractor)
Date 04-13-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627