

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340.

NOTICE OF INTENT NO. 10155

1. OWNER CAL NEU PIPELINE ADDRESS AT WELL LOCATION CAL NEU PIPELINE
MAILING ADDRESS C/O Condense Consultants Corner of Valley View & Hacienda
4670 S. Polaris Ave., Las Vegas Las Vegas, Nevada
2. LOCATION SE 1/4 NE 1/4 Sec. 30 T. 21 N. 61 E Clark County
PERMIT NO. MO-2262 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sandy gravel		0'	4'	4'
caliche		4'	16'	12'
gravelly sand		16'	35'	19'
caliche		35'	37'	2'
gravelly sand		37'	44'	7'
caliche		44'	50'	6'
gravelly sand		50'	55'	5'
SILTY CLAY		55'	98'	43'

8. WELL CONSTRUCTION
Depth Drilled 98 Feet Depth Cascd 80 Feet
HOLE DIAMETER (BIT SIZE)
From 10 Inches To 0 Feet
From 8 Inches To 60 Feet
From 0 Inches To 98 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	2 lbs	sch. 40	0	80

Perforations:
Type perforation factory slotted
Size perforation 0.020
From 40 feet to 80 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 0.35 / 33.35 Feet Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 35 feet to 80 feet

9. WATER LEVEL
Static water level Approx. 60' feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Richard LeBlanc Contractor
Address 4670 S. Polaris Ave.
Las Vegas, Nevada. 89103
Nevada contractor's license number issued by the State Contractor's Board _____
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1817
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 04.13.93

Date started 02.31 1993
Date completed 04.02 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
MAY 04 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

