



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 11805

1. OWNER Ronald Sharp ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SE 1/4 SE 1/4 Sec. 36 T. 19-S N/S R. 52 E Nye County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Brown Clay		4	26	22
Black Colored Clay		26	44	18
Light Grey Clay	x	44	82	38
Brown Clay		82	104	22
Soft Brown Clay	x	104	158	54
Brown Clay		158	178	20
Gravel /Clay		178	192	14
Soft Grey Clay	x	192	200	8

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
	18 lbs.	.188	0	200

Perforations:  
 Type perforation Torch Cut  
 Size perforation 1/4 in width 8 in long  
 From 160 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
 MAY 26 1993  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 200 feet

9. WATER LEVEL  
 Static water level 36 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started May 19, 1993  
 Date completed May 20, 1993

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	1/4

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Charles Nyberg Contractor  
 Address HCR 73 Box 36525 Contractor  
 Nevada contractor's license number 7484 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 725 Division of Water Resources, the on-site driller  
 Signed Charles Nyberg  
 By driller performing actual drilling on site or contractor  
 Date 5-22-93