

OFFICE USE ONLY
 Log No. 9253
 Permit No. 112
 Basin 112
 NOTICE OF INTENT NO. 10839

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Earl Adkins ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 NE 1/4 Sec 24 T. 20 N/S R. 52 E. Nye County _____
 PERMIT NO. 28-771-04 Issued by Water Resources Parcel No. _____ Subdivision Name Charleston Park

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay		0	4	4
caliche		4	6	2
clay		6	15	9
caliche		15	17	2
clay		17	35	18
caliche		35	38	3
clay		38	49	11
caliche	WB	49	51	2
clay		51	77	26
caliche	WB	77	81	4
clay		81	107	26
caliche	WB	107	109	2
clay		109	121	12
caliche	WB	121	123	2
clay		123	140	17

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation Factory Saw cut
 Size perforation 1 1/8 V3
 From 120 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

RECEIVED
 MAY 27 1993

Div. of Water Resources
 Branch Office - Las Vegas, NV
 Date started 5-3 1993
 Date completed 5-7 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 48 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address Hwy 78 Box 80354 Contractor
Phonix NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 35880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Dan
 By driller performing actual drilling on site or contractor
 Date 5-24-93