

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 41280
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 11722

1. OWNER Gerald Hergenrother ADDRESS AT WELL LOCATION Lot 8 Money St
 MAILING ADDRESS _____
 2. LOCATION SW 1/4 NE 1/4 Sec 11 T 21S N/S R 53 E Nye County
 PERMIT NO. 44-294-11 Parcel No. Joyceelyn Est. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	12	12
caliche		12	14	2
clay		14	32	18
caliche		32	35	3
clay		35	57	22
caliche	WB	57	59	2
clay		59	85	26
caliche	WB	85	87	2
clay		87	103	16
caliche	WB	103	105	2
clay		105	126	21
caliche	WB	126	129	3
clay		129	136	7
caliche	WB	136	140	4

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 3/4</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation Factory Saw cut
 Size perforation 1/2 x 3/8
 From 120 feet to 140 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

RECEIVED
 MAY 05 1993
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 4-26, 1993
 Date completed 4-29, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 36 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HCR 78 Box 80358 Contractor
Phump NV 89001
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Daw
 By driller performing actual drilling on site or contractor
 Date 4-30-93