

Log No. 41285
 Permit No. _____
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10845

1. OWNER Tom Terry Homes ADDRESS AT WELL LOCATION Saddletree Ln
 MAILING ADDRESS _____
 2. LOCATION NE 1/4 SE 1/4 Sec 16 T. 21S N/S R. 54 E Nye County
 PERMIT NO. 43-071-12 Cottonwoods Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cobbles		0	26	26
CLAY		26	41	15
Caliche		41	43	2
CLAY		43	61	18
Gravel-clay		61	92	31
Caliche	WB	92	94	2
Limestone	WB	94	105	11
CLAY		105	130	25
Caliche	WB	130	133	3
clay		133	159	26
Caliche	WB	159	161	2
CLAY		161	176	15
Caliche	WB	176	180	4

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 190 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 7/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>180</u>

Perforations:
 Type perforation Factory Sawcut
 Size perforation 1/4 V3
 From 160 feet to 180 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 180 feet

9. WATER LEVEL
 Static water level 91 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address Herz Box 80358 Prhrump NV 89041 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Durr
 By driller performing actual drilling on site or contractor
 Date 6-1-93

Date started 5-12 1993
 Date completed 5-14 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

RECEIVED

JUN 09 1993

Div. of Water Resources
 Branch Office - Las Vegas, NV

