

Log No. 41288
 Permit No. _____
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16944

1. OWNER Karney Mae Young ADDRESS AT WELL LOCATION 7730 SWildhorse
 MAILING ADDRESS _____
 2. LOCATION SE 1/4 SE 1/4 Sec 19 T. 21S N/S R. 54 E. Nye County
 PERMIT NO. _____ Issued by Water Resources Parcel No. 45-244-25 Subdivision Name Green Saddle

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	8	8
caliche		8	11	3
Clay		11	19	8
caliche		14	23	4
Clay		23	52	29
caliche		52	55	3
Clay		55	65	10
caliche	wB	65	68	3
Clay		68	83	15
caliche	wB	83	85	2
Clay		85	100	15
caliche	wB	100	104	4
Clay		104	112	8
caliche	wB	112	114	2
Clay		114	123	9
caliche	wB	123	125	2
Clay		125	134	9
caliche	wB	134	140	6

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 7/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

 Perforations:
 Type perforation Factory Saw cut
 Size perforation 1/8 x 3
 From 120 feet to 140 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

RECEIVED

JUN 09 1993

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 5-17, 1993
 Date completed 5-21, 1993

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL
 Static water level 58 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HC 278 Box 80354
Phonny NV 89041 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 36880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Dan
 by driller performing actual drilling on site or contractor
 Date 6-1-93

