WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41315
Permit No. 57156
Basin 212

NOTICE OF INTENT NO. 10719

1. OWNER Mike Delfonte
MAILING ADDRESS 6770 Farm Rd.
Las Vegas, Nev. 89131

ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ SW ¼ Sec. 15 T 19S N/S R 60 E Clark County
PERMIT NO. 57156 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	5	
Caliche (Popcorn)		5	160	
Clay		160	240	
Clay & Water		240	245	
Clay		245	340	
Clay & Water		340	360	
Clay		360	535	
Clay & Water		535	550	
Hard Limestone		550	590	
Clay & Water		590	616	

RECEIVED
MAY 25 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 5/18/93, 19
Date completed 5/20/93, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 616 Feet Depth Cased 616 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4"	Inches	0 Feet	55 Feet
10 5/8"	Inches	55 Feet	616 Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"	16.94	.188	+1	616

Perforations:
Type perforation Factory
Size perforation 3/16 x 8 row
From 574 feet to 594 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 125 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick (Contractor)
Address 3035 S. Torrey Pines (Contractor)
Las Vegas, Nevada 89102
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V H Dimick (By driller performing actual drilling on site or contractor)
Date 5-26-93

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627