

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY  
 Log No. 4324  
 Permit No. 54997  
 Basin 212

NOTICE OF INTENT NO. 10704

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER James P. Causey ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 8585 W. Washburn  
Las Vegas 89129 N/A  
 2. LOCATION E 1/4 SW 7 1/4 SE 1/4 Sec 29 T 19 N/S R60 E Clark County  
 PERMIT NO. 54997  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel		0	26	
Cemented Gravel		26	32	
Gravel		32	90	
Clay & Gravel		90	340	
Gravel & Water	xx	340	400	

8. WELL CONSTRUCTION  
 Depth Drilled 400 Feet Depth Cased 400 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
12 1/4" Inches 0 Feet 55 Feet  
10 5/8" Inches 55 Feet 400 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8"</u>	<u>16.94</u>	<u>.188</u>	<u>+2</u>	<u>400</u>

Perforations:  
 Type perforation Factory  
 Size perforation 3/16" x 8" row  
 From 360 feet to 380 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
 APR 29 1993  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 55  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 1.95 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 4/19/93, 19\_\_\_\_\_  
 Date completed 4/24/93, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Vernon Dimick Contractor  
 Address 3035 S. Torrey Pines  
Las Vegas Nev. 891022  
 Nevada contractor's license number 10062  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 552  
 Division of Water Resources, the on-site driller  
 Signed V. Dimick  
 By driller performing actual drilling on site or contractor  
 Date 4-29-93