WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41327
Permit No. 56168
Basin 212

NOTICE OF INTENT NO. 10711

1. OWNER Keith Hafen
MAILING ADDRESS 4965 Durango Dr
Las Vegas NV 89129

ADDRESS AT WELL LOCATION N/A

2. LOCATION NW ¼ NW ¼ Sec. 30 T. 19S N/S R. 60 E. Clark County
PERMIT NO. 56168 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	95	
Cemented Gravel		95	110	
Boulders		110	130	
Gravel		130	400	
Gravel & Clay		400	485	
Cemented Gravel		485	530	
Gravel & Water	xx	530	540	
Cemented Gravel		540	560	
Gravel & Water	xx	560	600	

RECEIVED
MAY 18 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 5-11-93, 19
Date completed 5-14-93, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 600 Feet Depth Cased 600 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 1/4" Inches	0 Feet	55 Feet
10 5/8" Inches	55 Feet	600 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"	16.94	.188	+2	600

Perforations:
Type perforation Factory
Size perforation 3/16 x 8 row
From 560 feet to 580 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 415 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick (Contractor)
Address 3035 S. Torrey Pines (Contractor)
Las Vegas, Nev. 89102
Nevada contractor's license number 10062 issued by the State Contractor's Board
Nevada driller's license number 552 issued by the Division of Water Resources, the on-site driller
Signed (By driller performing actual drilling on site or contractor)
Date 5-14-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627