WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41333
Permit No.
Basin 212

NOTICE OF INTENT NO. 11939

1. OWNER MAGIC WAND
MAILING ADDRESS c/o CONVERSE CONSULTANTS 4670 S. POLARIS AV. LV, NV 89103
ADDRESS AT WELL LOCATION MAGIC WAND 1100 E. COLTON AV. N. LAS VEGAS, NV

2. LOCATION NW ¼ SE ¼ Sec. 11 T. 20 N/S R. 61 E. CLARK County
PERMIT NO. M0-2077A (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVELLY SAND		0	15	15
SILTY SAND		15	21	6
CALICHE		21	23	2
SILTY SAND		23	27	4
SILTY CLAY		27	44	17
SANDY CLAY		44	50	6
SILTY CLAY		50	60	10

RECEIVED
MAY 11 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started APRIL 23, 19 93
Date completed APRIL 23, 19 93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 60 Feet Depth Cased 60 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 Inches	0 Feet	60 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	.7 lbs	SCH 40	0	60

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 0.020
From 30 feet to 60 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-27 / 25-27 BENT
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 27 feet to 60 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DON WILSON (Contractor)
Address 4670 S. POLARIS AV (Contractor)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1589
Signed (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91)
USE ADDITIONAL SHEETS IF NECESSARY
(O) 627