

OFFICE USE ONLY
 Log No. 41387
 Permit No. 212
 Basin 212
 NOTICE OF INTENT NO. MW-95

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Nellis Air Force Base ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS FWC / EV Bldg 899
Nellis AFB, NV 89191 5000
 2. LOCATION NE 1/4 NE 1/4 Sec 1 T 20 N 62 E Clark County
 PERMIT NO. MO-2231 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE Monitoring
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Silty SAND</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>Silty GRAVEL</u>		<u>5</u>	<u>20</u>	<u>15</u>
<u>gravelly SILT</u>		<u>20</u>	<u>30</u>	<u>10</u>
<u>Silty GRAVEL</u>		<u>30</u>	<u>45</u>	<u>15</u>
<u>gravelly SILT</u>		<u>45</u>	<u>102</u>	<u>57</u>
<u>clayey SILT</u>		<u>102</u>	<u>144</u>	<u>42</u>

8. WELL CONSTRUCTION
 Depth Drilled 144 Feet Depth Cased 139 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8.25 Inches To 0 Feet 139 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.5</u>	<u>-</u>	<u>0.18</u>	<u>0</u>	<u>139</u>

Perforations:
 Type perforation Sch 80 PVC
 Size perforation 0.02 - inch
 From 109 feet to 139 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 104.5 feet to 144 feet

RECEIVED
 JUN 01 1993
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 3/9 1993
 Date completed 3/15 1993

7. N/A WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 124.80 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name H-F Drilling, Inc. Contractor
 Address 1150 W. Trenton Avenue Contractor
Orange, CA 92667
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1747
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 5/18/93