WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41388
Permit No.
Basin 212

NOTICE OF INTENT NO. MW-96

1. OWNER Nellis Air Force Base
MAILING ADDRESS FWC/EV Bldg 899
Nellis AFB, NV 89191-5000
ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ NW ¼ Sec. 3 T. 20 N/S R. 62 E. Clark County
PERMIT NO. MO-2231 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test (Monitoring)
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clayey SILT		0	5	5
silty CLAY		5	23	18
gravelly SILT		23	28	5
silty CLAY		28	40.5	12.5
clayey SILT		40.5	45	4.5
silty CLAY		45	46	1
caliche		46	49	3
silty CLAY		49	60	11
clayey SILT		60	65	5
silty CLAY		65	75	10
gravelly SILT		75	80	5
silty CLAY		80	96	16
clayey SILT		96	100	4
silty CLAY		100	101.5	1.5

RECEIVED
JUN 01 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 2/6, 1993
Date completed 2/7, 1993

7. N/A WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 101 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8.25 Inches	0 Feet	101 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.5	—	0.18	0	100

Perforations:
Type perforation Sch 80 PVC
Size perforation 0.02 inch
From 70 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 64'
Placement Method: ☒ Pumped ☐ Poured

Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 68 feet to 101 feet

9. WATER LEVEL
Static water level 80.0 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H-F Drilling, Inc. (Contractor)
Address 1150 W. Trenton Avenue (Contractor)
Orange, CA 92667
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1747
Signed (By driller performing actual drilling on site or contractor)
Date 5/18/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627