WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41396
Permit No.
Basin 212
MW-4

NOTICE OF INTENT NO. 11361

1. OWNER HESMAT Mohajerani
MAILING ADDRESS 8729 Double Eagle Dr
LAS VEGAS NV 89117

ADDRESS AT WELL LOCATION Chapel of Love
1431 Las Vegas Blvd South
LAS VEGAS NV

2. LOCATION SW ¼ NW ¼ Sec. 3 T. 21 N/S R. 61 E CLARK County

PERMIT NO. MO-2227 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☒ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		0	.10	0.10
Fill		0.10	3	2.90
Silty Clay		3	5.5	2.5
Clay		5.5	8.5	3.0
Silty Clay w/sand		8.5	12	3.5
Sandy silt w/clay		12	14.5	2.5
Clay w/silt		14.5	16	1.5
CALICHE		16	17	1.0
Silty Clay w/gravel		17	19	20
Clay w/silt		19	25	6

RECEIVED
MAY 11 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 5-7, 1993
Date completed 5-7, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	25 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	0.700		0	25

Perforations:
Type perforation Factory Slotted
Size perforation 0.020
From 5 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 3
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 3 feet to 25 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Don Wilson / Conners Consultants (Contractor)
Address 4670 S. Paloma Ave (Contractor)
LAS VEGAS NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589
Signed (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627