WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41406
Permit No.
Basin 212

NOTICE OF INTENT NO. 10931

1. OWNER National Ground Water Assocation
MAILING ADDRESS 6375 Riverside Drive/Dublin, OH 43017
ADDRESS AT WELL LOCATION Corner of Paradise Road and Rivera Boulevard in Los Vegas Nevada

2. LOCATION NE ¼ SE ¼ Sec. 9 T. 21 N/S R. 61 E. E Clark County
PERMIT NO. MO 2289 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy top Soil Fill		0	5	5
Caleche Hard		5	6	1
Clay Sand & Gravel	12'	6	17	11
Sand & Gravel		17	20	3
Clay to Sandy Clay		20	28	8
Caleche " "		28	31	3
white Clay		31	34	3
Caleche		34	35	1
Clay		35	37	2
Sand Gravel Coarse		37	39	2
Clay		39	40	1

RECEIVED
JUN 01 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started May 24, 1993
Date completed May 24, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10	27	1-hour

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
18 Inches	0 Feet	40 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"	sch 40	PVC	0	40'

Perforations:
Type perforation slot sch 40 PVC
Size perforation 0.020 of an inch
From 20' feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 18' feet to 40 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality poor

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Griffin Dewatering by Carroll Lane (Contractor)
Address 536 East Maitland street Ontario California 91761 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0031246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller
Signed Carroll Lane Griffin Dewatering
By driller performing actual drilling on site or contractor
Date 5/24/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627