WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 41407
Permit No.
Basin 212

NOTICE OF INTENT NO. 10152

1. OWNER WARTHEN BUICK
MAILING ADDRESS C/O BROADBENT & ASSOC.
893 NEVADA HWY, B.C., NV 89005

ADDRESS AT WELL LOCATION WARTHEN BUICK
3025 E. SAHARA AV.
LAS VEGAS, NV 89121

2. LOCATION NW ¼ NW ¼ Sec. 12 T 21 N/S R 61 E CLARK County

PERMIT NO. MD-22666 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other AUGER

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| ASPHALT | | 0 | 0.5 | 0.5 |
| PEA GRAVEL | | 0.5 | 9.5 | 9 |
| SILTY GRAVEL | | 9.5 | 12 | 2.5 |
| SILTY CLAY W/GRAVEL | | 12 | 15 | 3 |
| SILTY CLAY | | 15 | 20 | 5 |

RECEIVED
MAY 11 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started MARCH 25, 1993
Date completed MARCH 25, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 8 Inches | | 0 Feet | 20 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2" | .7 lbs | SCH 40 | 0 | 20 |
| | | | | |
| | | | | |

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 0.020
From 5 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-4 / 3-4 BENT.
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 4 feet to 20 feet

9. WATER LEVEL
Static water level 10.46 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RICHARD LEBLANC Contractor
Address 4670 S. POLARIS AV. Contractor
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources (the on-site driller) M-1817
Signed By driller performing actual drilling on site or contractor
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627