WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 414176
Permit No. 25398
Basin 212

NOTICE OF INTENT NO. 11678

1. OWNER Sparkletts Drinking Water Corp.
MAILING ADDRESS c/o Allen Drilling
4847 Valley View, Las Vegas, NV 89103

ADDRESS AT WELL LOCATION
4225 W. Desert Inn

2. LOCATION NW ¼ NE ¼ Sec. 18 T. 21 S R. 61 E. Clark County

PERMIT NO. 25398 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Commercial/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill dirt		0	5	5
Caliche		5	9	4
Sandy clay		9	20	11
Clay		20	40	20
Clay, some rock		40	160	120
Clay		160	168	8
Sand		168	179	11
Sandy clay		179	220	41
Clay		220	223	3
Sand & gravel		223	240	17
Sand, gravel & clay		240	274	34
Hard clay		274	334	60
Rock		334	340	6
Sand, gravel & clay		340	540	200
Partly cem. sand & gravel		540	850	310

RECEIVED
MAY 14 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started March 12, 19 93
Date completed May 6, 19 93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 850 Feet Depth Cased 850 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches	0 Feet	850 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.90	.188	+1	850

Perforations:
Type perforation Stainless steel screen
Size perforation .080 slot
From 760 feet to 830 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 850 feet

9. WATER LEVEL
Static water level 164 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name THOMPSON DRILLING CO., INC. (Contractor)
Address 4185 West Harmon (Contractor)
Las Vegas, NV 89103

Nevada contractor's license number issued by the State Contractor's Board 82 4286A

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 856

Signed Richard K. Thompson (By driller performing actual drilling on site or contractor)

Date May 12, 1993

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627

016