

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 11973

1. OWNER Western Summit ADDRESS AT WELL LOCATION 206 Athens Ave
MAILING ADDRESS 5470 Valley Highway Henderson NV
Denver Co. 80210
2. LOCATION SE 1/4 Sec 36 T 21 N 8 R 6 E Clark County
PERMIT NO. 70700 DV-1007 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other Bucket

6. LITHOLOGIC LOG

Well No #	Material	Water Strata	From	To	Thick-ness
	SANDY w/ROCKS		0	8	8
	SANDY w/CLAY		8	11	3
	SANDY w/GRANUL		11	19	8
	SANDY w/ fine GRAVEL		19	25	6
	Green Clay		25	27	2
	w/ SAND				
	Green Clay		27	35	8
	White Clay		35	40	5

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet
HOLE DIAMETER (BIT SIZE)
From 24 Inches To 40 Feet
Inches Feet Feet Feet
Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12			0	40

Perforations:
Type perforation SAN CUT
Size perforation 0.40
From 20 feet to 40 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
Depth of Seal _____ Cement Grout
Placement Method: Pumped Concrete Grout
 Poured
Gravel Packed: Yes No
From 0 feet to 40 feet

RECEIVED

MAY 19 1993

Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 1-27, 1993
Date completed 1-27, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name FOOT HILLS Eng Contractor
Address 905 E 3rd ST Contractor
CORONA Cal
Nevada contractor's license number issued by the State Contractor's Board _____
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1567
Signed Chuck W. Sam
By driller performing actual drilling on site or contractor
Date 1-27