

OFFICE USE ONLY
 Log No. 41454
 Permit No. 212
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 11972

1. OWNER Western Summit ADDRESS AT WELL LOCATION 200 ATHENS AVE Henderson NV
 MAILING ADDRESS 5470 Valley Highway Denver Co. 80216

2. LOCATION SE 1/4 36 T 21 N 62 E Clark County
 PERMIT NO. DW 1007 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Bucket

6. LITHOLOGIC LOG

well #	Material	Water Strata	From	To	Thick-ness
12#	SANDY W/ COBEL		0	11	11
	SAND W/ GRAVEL		11	20	9
	COBEL		20	25	5
	BROWN CLAY		25	31	6
	GREEN CLAY		31	40	9

8. WELL CONSTRUCTION
 Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)
 From 24 Inches To 40 Feet
 From 0 Feet To 40 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12			0	40

Perforations:
 Type perforation SAW CUT
 Size perforation 1/4"
 From 20 feet to 40 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 0 feet to 40 feet

9. WATER LEVEL
 Static water level 12 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Foot Hills Eng Contractor
 Address 205 E Blvd ST Contractor
Clark Co. NV
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1567
 Signed Chuck W. Sewell
 By driller performing actual drilling on site or contractor
 Date 1-28

Date started 1-28, 1993
 Date completed 1-28, 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
 MAY 19 1993
 Div. of Water Resources
 Branch Office - Las Vegas, NV

