WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41457
Permit No. 56901
Basin

NOTICE OF INTENT NO. 10702

1. OWNER Edith Eakin
MAILING ADDRESS 5585 Palm Ave
Las Vegas Nev. 89102
ADDRESS AT WELL LOCATION N/A

2. LOCATION NW ¼ NW ¼ Sec 22 T 22 N/S R 60 E Clark County
PERMIT NO. 56901 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	2	
Cemented Gravel		2	6	
Gravel		6	45	
Cemented Gravel		45	75	
Gravel & Clay		75	130	
Cemented Gravel		130	180	
Gravel & Clay		180	585	
Hard Sandstone		585	680	
Hard Sandstone & Wate xx		680	720	
Hard Sandstone		720	805	

RECEIVED
MAY 13 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 3/31/93, 19
Date completed 4/17/93, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 805 Feet Depth Cased 805 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 1/4" Inches	0 Feet	55 Feet
10 5/8" Inches	55 Feet	805 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"	16.94	.188	+2	805

Perforations:
Type perforation Factory
Size perforation 3/16 x 8 rw
From 760 feet to 780 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 55
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 525 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick (Contractor)
Address 3035 S. Torrey Pines (Contractor)
Las Vegas, Nevada 89102
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V H Dimick (By driller performing actual drilling on site or contractor)
Date 5-6-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627