

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 41468  
 Permit No. 51028  
 Basin 212  
 NOTICE OF INTENT NO. 11683

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER Alfred R. Anton Rando ADDRESS AT WELL LOCATION 755 Sherrie Lane  
 MAILING ADDRESS P.O. Box 8017  
Las Vegas, NV 89119  
 2. LOCATION NE 1/4 SE 1/4 Sec. 25 T. 22 S. R. 61 E Clark County  
 PERMIT NO. 51028 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  Monitor  Stock  
 Quasi  Municipal/Industrial

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Boulders		0	100	100
Lava rock & boulders		100	140	40
Red sandy clay		140	400	260
Brn. sandy clay, some grav.		400	660	260
Brown clay		660	780	120
Brn. clay & gravel		780	800	20
Gravel layers		800	840	40
Clay & gravel		840	885	45

8. WELL CONSTRUCTION  
 Depth Drilled 885 Feet Depth Cased 885 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/2 Inches To 0 Feet 885 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.90	.188	+1	885

Perforations:  
 Type perforation Torch cut  
 Size perforation 1/8"  
 From 805 feet to 885 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 885 feet

9. WATER LEVEL  
 Static water level 550 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name THOMPSON DRILLING CO., INC. Contractor  
 Address 4185 West Harmon Contractor  
Las Vegas, NV 89103  
 Nevada contractor's license number issued by the State Contractor's Board 4286A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1489  
 Signed Richard K. Thompson  
 By driller performing actual drilling on site or Contractor  
 Date June 4, 1993

Date started April 10, 1993  
 Date completed May 27, 1993

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED  
 JUN 10 1993  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV